
VAUGHAN COMPANY OFF LOADING AND LONG-TERM STORAGE INSTRUCTIONS SE SUBMERSIBLE PUMPS

OFF LOADING AND INSPECTION INSTRUCTIONS:

Prior to shipment Vaughan pumps are carefully crated and inspected to ensure arrival at your site in good condition. On receiving your pump, examine it carefully to assure that no damaged crating or broken parts have resulted from mishandling during shipping. Look for signs that the pump has been dropped, such as missing paint, dented flanges, cracked housings, or leaking oil. Turn the pump shaft by hand and verify that it turns over smoothly. If the shaft binds, look for debris between impeller and cutter bar. Otherwise, shaft binding could indicate damage. If damage has occurred, report to your carrier immediately, and consult your local Vaughan representative or call Vaughan Co. for advice.

| OFFLOADING | CONFIRMATION | NAME & DATE |
|---|--------------|-------------|
| Receipt inspection notes no damage and pump shaft is confirmed to turn by hand? | Yes___ No___ | |

STORAGE REQUIREMENTS TO BE UNDERTAKEN BY CONTRACTOR:

If equipment is to be stored for longer than two weeks, take the following action:

1. Coat exposed steel with a light layer of grease or protective spray-on lubricant to protect the equipment from corrosion.
2. Rotate the motor 1-¼ turn once each week to keep the bearings from sitting in one position for extended periods of time.
3. Avoid storing rotating equipment near other vibrating equipment. The vibrations can cause damage to the ball bearings and cause premature failure once the equipment is started up.
4. Store rotating equipment in a clean, dry, heated area away from areas where it could be damaged from impact, smoke, dirt, vibration, corrosive fumes or liquids, or from condensation inside the motor or pump. It is helpful to cover equipment with plastic.

| STORAGE | CONFIRMATION | NAME & DATE |
|--|--------------|-------------|
| Protective coating was applied? | Yes___ No___ | |
| Equipment is not stored near any vibrating equipment? | Yes___ No___ | |
| Equipment is stored in a clean, dry, heated indoor area? | Yes___ No___ | |

All storage & maintenance log records must be retained and made available to the factory upon request.



RECORD OF MONTHLY OPERATIONAL MAINTENANCE

- SHEET __ OF __ SHEETS -

-

PROJECT: _____

LOCATION: _____

PUMP MODEL: _____

PUMP SERIAL NUMBER: _____

START-UP DATE: _____

| | NAME & DATE | AMPERAGE DRAW | DISCHARGE PRESSURE (PSI) |
|----------|-------------|---------------|--------------------------|
| MONTH 1 | | | |
| MONTH 2 | | | |
| MONTH 3 | | | |
| MONTH 4 | | | |
| MONTH 5 | | | |
| MONTH 6 | | | |
| MONTH 7 | | | |
| MONTH 8 | | | |
| MONTH 9 | | | |
| MONTH 10 | | | |
| MONTH 11 | | | |
| MONTH 12 | | | |

All storage & maintenance log records must be retained and made available to the factory upon request.



RECORD OF ANNUAL OPERATIONAL MAINTENANCE

ANNUAL MAINTENANCE IS TO BE PERFORMED IN ADDITION TO MONTHLY MAINTENANCE

| | NAME & DATE | PUMP REMOVED FROM PIT AND INSPECTED FOR WEAR OR DAMAGE? | CLEARANCES CHECKED BETWEEN IMPELLER AND CUTTER BAR? | SMOOTH ROTATION AND NO AXIAL PLAY OF SHAFT? |
|--------|-------------|---|---|---|
| YEAR 1 | | Yes___ No___ | Yes___ No___ | Yes___ No___ |

| | NAME & DATE | PUMP CASING OR ADAPTER BRACKET WORN? | LOOSE, CORRODED OR WORN HARDWARE? |
|--------|-------------|--------------------------------------|-----------------------------------|
| YEAR 1 | | Yes___ No___ | Yes___ No___ |

All storage & maintenance log records must be retained and made available to the factory upon request.